





Minutes for meeting for Pre- bid conference for tender no. GEM/2025/B/6124308 for Multipurpose Fire Tender (MFT):

Sr.no.	Firm Name	Reference Clause of tender	Description of query	ISP reply
1	(Representation Raised on GEM)	4. Pumping station	<p>The pump fitted on the MFT shall be a Godiva/Rosenbauer or equivalent (CE certified/ UL listed), centrifugal pump</p> <p><b>Proposed for:</b> Consider firefly make pump with CE/UL list as equivalent make</p> <p>The OEM priming system shall be capable of lifting water from 7 Mtrs. depths within 30 seconds when tested.</p>	No change, any CE/UL listed make pump is acceptable.
		4.7 pumping priming system	<p><b>Proposed for:</b> Pump priming system shall be capable of lifting water from 7 Mtrs. depths within 30 seconds with 100 mm dia suction and 36 sec within 140mm dia suction</p> <p>The jet range shall be approx. 30 Mtrs. (in still air condition).</p>	No change, as per tech spec.
		7.1 Hose Reels & Fog Guns	<p><b>Proposed for:</b> The jet range shall be approx. 20 to 25 Mtrs. (in still air condition).</p>	No change, as per tech spec.
		12.1. Seating	<p>The seats shall be of Ziamatic, USA/ Seats Inc (Battalion SCBA Crew Flip Seat) or equivalent make only.</p> <p><b>Proposed for:</b> Consider, The seats shall be HO- Bostrom, USA make as equivalent make.</p>	No change, any equivalent make is acceptable.
		13.1 TELESCOPIC LIGHT MAST	<p>a) A compact, low profile, roof mounted lighting system. fitted with 4 x 1000 watts latest technology LED light lamps, vertically elevated pneumatically up to 15 feet (4.6 m) shall be installed on the roof of the vehicle.</p> <p>b) Lighting shall be provided through chassis power only 24 V DC (Generator is not required) with Remote and manual control, directional lighting system with rotation&amp; tilt lamps to provide total coverage.</p>	No change, as per tech spec.

*Handwritten signature in blue ink*

*Handwritten signature in blue ink with date 13/08/25*

		<p><b>Proposed for:</b> roof mounted lighting system. fitted with 4 x 100 watts latest technology LED light lamps as 4 x 1000 watts LED lamps not available and not power from 24 V DC (as generator is not required)</p>	
	16. Accessories to be supply with multipurpose fire tender- point 42	<p>Mobile VHF Set (to be fixed on cabin)</p> <p>Asked for : Confirm to provide frequency license of consignee for Mobile VHF Set</p>	<p><b>No change</b> (ISP will provide all relevant documents and license has to be arranged by the bidder on behalf of ISP)</p>
	Delivery schedule	160 days	No change
		<b>Proposed for : 210 days</b>	

Sr.no.	Name of ISP officials attending the pre- bid conference	Signature
1	Shri. Mangesh Kasvekar, JGM(TO)-P	
2	Shri. Shailesh Awachat, JGM(TO)	
3	Shri. Meraj Ahmad, M(TO)	
4	Shri. Vijay Sonavane, AC (Fire)	
5	Shri. S.K. Ojha, Inspector (Fire)	